

10. QUALITY

10.1 Specifications. The Gas delivered by either party to the other hereunder shall meet the quality specifications of the Transporter having the then-current most stringent quality specifications which receives or delivers such Gas at the Point(s) of Receipt or Point(s) of Delivery located on Egan Hub's system, as applicable, and, unless such Transporter's quality specifications are more stringent, shall be of such quality that it shall meet at least the following specifications:

- (a) Be commercially free from objectionable odors, dirt, dust, iron particles, gums, gum-forming constituents, gasoline, PCB's, and other solid and/or liquid matter, including but not limited to water, Gas treating chemicals and well completion fluids and debris, which may become separated from the Gas during the transportation thereof.
- (b) Contain not more than one fourth (1/4) of one grain of hydrogen sulphide per one hundred (100) Cubic Feet of Gas, as determined by the cadmium sulfate quantitative test, nor more than twenty (20) grains of total sulphur per one hundred (100) Cubic Feet of Gas.
- (c) The Gas delivered hereunder shall not contain more than two-tenths of one percent (0.2%) by volume of oxygen, shall not contain more than three percent (3%) by volume of carbon dioxide, shall not contain more than three (3%) by volume of nitrogen, and shall not contain a combined total of carbon dioxide and nitrogen components of more than four (4%) by volume.
- (d) Have a heating value of not less than nine hundred and sixty-seven (967) Btu's per Cubic Feet of Gas and not more than eleven hundred (1100) Btu's per Cubic Feet of Gas.
- (e) Have a temperature of not more than one hundred twenty degrees Fahrenheit (120 degrees F), nor less than forty degrees Fahrenheit (40 degrees F).
- (f) Have been dehydrated by the tendering party, by any method other than the use of a calcium chloride as desiccant, for removal of entrained water in excess of seven (7) pounds of water per million (1,000,000) Cubic Feet of Gas as determined by dew-point apparatus approved by the Bureau of Mines or such other apparatus as may be mutually agreed upon.

10.2 Rejection of Gas. Either party shall be entitled to reject any Gas tendered to it by the other party which does not meet the minimum specifications of Section 10.1

hereunder. Acceptance of such Gas does not constitute any waiver of Egan Hub's right to refuse to accept similarly nonconforming Gas.